

# Interstitial Monitoring Log for Doublewalled Systems

Facility Name \_\_\_\_\_

Tank Size \_\_\_\_\_

Location \_\_\_\_\_

Product (s) \_\_\_\_\_

Date	Fuel?	Water?	Initials of Person Sampling Sump

**Instructions:** Use a clean stick, not one that has been used previously in an oil tank. At the very bottom of the stick, dab a small amount of gas paste one side and a small amount of water paste on the other side. Lower the stick to the bottom of the interstitial sump and raise it back up. If either gas paste or water paste has turned color, clean the stick and repeat the procedure. If either the gas paste or the water paste has again turned color then the Department should be promptly notified. Call 1-800-482-0777 as soon as possible and within 24 hours. If the paste has not changed color simply fill in the date in the left-hand column, enter "None" in the product and water columns above and put your initials in the right-hand column. Check weekly.

KEEP THIS COMPLETED FORM ON SITE FOR THREE YEARS